

Date: 18 Sep 2023

HSPCB/FORM-V/2022-2023/01

The Environmental Officer (Haryana)  
Haryana State Pollution Control Board  
3rd Floor, HSIIDC Complex,  
IMT Manesar, Gurugram

Dear Sir/Madam,

**Subject: Submission of Environmental Statement (Form-V) for Infosys Limited, Gurugram**

With reference to above subject, we herewith submit the Environmental Statement (Form –V) for FY 2022-23 for Infosys Limited, Gurugram.

Enclosed:

1. Form –V for FY 2022-23
2. Copy of stack monitoring report
3. Copy of ambient air quality report
4. Copy of STP outlet water testing report


Yours Sincerely,


For INFOSYS LIMITED

Puneet Randhawa

Senior Regional Head - Facilities

Date: 18 Sep 2023



  
Haryana State Pollution Control Board  
Gurgaon Region (South)  
HSIIDC Complex, 3rd Floor,  
IMT Manesar, Gurgaon

**INFOSYS LIMITED**  
Tower-B, Uniworld Towers  
Village-Tikri, Sec-48  
Gurugram  
Haryana 122 018, India

Corporate Office:  
CIN: L85110KA1981PLC013115  
44, Infosys Avenue  
Electronics City, Hosur Road  
Bengaluru 560 100, India



## ii. Raw material consumption

Name of raw materials*	Name of Products	Consumption of raw material per unit of output	
		During the previous financial year	During the current financial year
- NA-			

\* Industry may use codes if disclosing details of raw material would violate contractual obligations, otherwise all industries have to name the raw materials used.

## PART-C

### Pollution discharged to environment/unit of output

(Parameter as specified in the consent issued)

Pollutants	Parameters	Quantity of pollutants discharged (mass/day)	Concentration of pollutants discharged (Average)	Percentage of variation from prescribed standards with reasons
(a) Water	BOD	0.027 kg/day	6.7 mg/l	Within limits
	COD	0.113 kg/day	28 mg/l	
	TSS	0.034 kg/day	8.5 mg/l	
	Oil & Grease	<0.016 kg/day	<4 mg/l	
	pH	-	6.7	
(b) Air	Particulate Matter	0.065 kg/day	27.56 mg/Nm <sup>3</sup>	Within limits
	Sulphur Dioxide(SO <sub>2</sub> )	0.026 kg/day	11.12 mg/Nm <sup>3</sup>	
	Oxides of Nitrogen(NO <sub>2</sub> )	0.457 kg/day	192.47 mg/Nm <sup>3</sup>	
	Carbon Monoxide(as CO)	0.152 kg/day	64.13 mg/Nm <sup>3</sup>	

## PART-D

### Hazardous Waste

(As specified under Hazardous Wastes (Management & Handling Rules, 1989).

Hazardous Wastes	Total Quantity (Kg)	
	During the previous financial year	During the current financial year
(a) From process	353.6	650.3
(b) From pollution control facilities	Nil	Nil

## PART - E

### Solid Waste:

Solid Wastes	Total Quantity (Kg)	
	During the previous Financial year	During the current financial year
(a) From process	1384	811.7
(b) From pollution control facility	NA	NA
(c) (1) Quantity recycled or re- utilized within the unit (2) Sold (3) Disposed	NA	NA

## PART -F

**Please specify the characteristics (in terms of concentration and quantum) of hazardous as well as solid wastes and indicate disposal practice adopted for both these categories of wastes.**

(a) Hazardous waste (Used oil, used coolant, wastes or residues containing oil)- This was given to the authorized recycler (Om industries)

(b) Solid waste (Municipal solid waste-Mixed waste)- This was given to authorized waste collector (Ecogreen Energy)

## PART-G

**Impact of the pollution abatement measures taken on conservation of natural resources and on the cost of production.**

- NA-

## PART - H

**Additional measures/ investment proposal for environmental protection abatement of pollution, prevention of pollution.**

- (a) Energy conservation practices are implemented.
- (b) Usage of power and water is monitored and analyzed every month.
- (c) Efforts have been taken to minimise the use of plastic within the campus.
- (d) Trainings are given to the staff on environmental protection.
- (e) STP outlet water is used in landscaping and flushing purpose.

**PART-I**

**Any other particulars for improving the quality of the environment.**

- NA-

Date: 18 Sep 2023

Place: Gurugram



Signature: .....

Puneet Randhawa  
Senior Regional Head- Facilities