

IL/MYS/KSPCB/2025-26/006

Date: 26.09.2025

The Environmental Officer,  
Karnataka State Pollution Control Board  
#436 D, KIADB Industrial Area,  
KRS Road, Mysuru – 570 016

Subject: Submission of Form-V (Environmental Statement) for financial year 2024-25


Sir,

With reference to above subject, please find herewith enclosed the Form-V (Environmental Statement) for financial year 2024-25 of Infosys Limited, Mysore Development Center.

In anticipation of your favorable orders.

Cordially yours,

For INFOSYS LIMITED



AUTHORIZED SIGNATORY

Enclosures:

1. Environmental Statement in Form-V.
2. STP treated water analysis reports.
3. DG stack emission monitoring reports.
4. Ambient air quality analysis report.
5. Ambient noise level monitoring report.



INFOSYS LIMITED  
Plot No: 350  
Hebbal Electronics City  
Mysuru 570 027, India  
T 91 821 240 4101  
F 91 821 240 4200

Corporate Office:  
CIN: L85110KA1981PLC013115  
44, Infosys Avenue  
Electronics City, Hosur Road  
Bengaluru 560 100, India  
T 91 80 2852 0261  
F 91 80 2852 0362  
askus@infosys.com  
www.infosys.com

**FORM-V**  
**ENVIRONMENTAL STATEMENT**  
(See rule 14)

Environmental Statement for the financial year ending with 31<sup>st</sup> March 2025

**PART - A**

Sl. No.	Particulars	
1	Name and address of the owner/ occupier of the industry operation or process	Infosys Limited (Non-SEZ and SEZ) 350, Hebbal Electronic City, Hootagalli, Mysore – 570027
2	Industry category Primary-(STC Code) Secondary- (STC Code)	Not applicable
3	Production category – Units	Software Development
4	Year of establishment	2001
5	Date of the last environmental statement submitted.	20.09.2024

**PART - B**

**WATER AND RAW MATERIAL CONSUMPTION**

**1. Water Consumption**

Sl. No.	Water consumption for	Cubic meter per day (m <sup>3</sup> /day)
I	Process:	Not applicable
II	Cooling, Laundry, Back wash / rejects	41.62
III	Domestic:	651.20

Name of Products	Process water consumption per unit of products	
	During the previous financial year (2023-24)	During the current financial year (2024-25)
Not applicable		

**2. Raw Material Consumption**

Name of raw materials	Name of Products	Consumption of raw material per unit of output	
		During the previous financial year (2023-24)	During the current financial year (2024-25)
Not applicable			

## PART-C

### Recycled water from STP

Pollutants	Quantity of pollutants discharged (mass/day) in Kg/day	Concentration of pollutants discharged (mass / volume) – Average of quarterly reports			% of variations from prescribed standards with reasons
		STP-1	STP-2	STP-3	
pH	--	STP is not operational due to low flow due to limited occupancy in the campus	7.81	7.74	Discharged parameters are well within the prescribed standards
BOD	2.038		3 mg/l	2 mg/l	
COD	12.448		19.5 mg/l	12 mg/l	
TSS	BDL		BDL	BDL	
NH4-N	0.84		0.59	0.705 mg/l	
Total Nitrogen	5.254		4.18	5.797 mg/l	
Oil & Grease	BLQ		BLQ	BLQ	
E-Coli*	Absent		Absent	Absent	
Total Coliform*	Absent		Absent	Absent	

Note:

BDL – Below Detectable Level;

BLQ – Below the Limit of Quantification;

\* UOM is MPN/100ml

DL – Detectable Level (DL is 2 mg/l)

LOQ - Limit of Quantification (LOQ is 2 mg/l)

Recycled water analysis report – copy of one quarter is enclosed.

### Air emission from DG set

Pollutants	Quantity of pollutants discharged (mass / day) Kg / day *	Concentration of Pollutants discharged (mass / Volume) in mg/Nm <sup>3</sup>			% of variations from prescribed standards with reasons
		Power Block-1**	Power Block-2**	Power Block-3**	
SPM	0.40	21.25	23.92	25.51	Discharged parameters are well within the prescribed standards
SO <sub>2</sub>	0.35	22.09	19.71	18.98	
Oxides of Nitrogen (NOx)	0.85	53.16	49.20	46.60	
Carbon monoxide (CO)	1.32	68.40	78.96	83.97	
Non-Methyl Hydrocarbon (NMHC)	0.36	19.58	21.04	21.80	

Note:

\* Cumulative value of all DG sets across power blocks put together

\*\* Average concentration of emission from DG sets of respective Power Blocks during the financial year FY24-25

Stack monitoring analysis sample report of all the DG sets for the month of Mar'25 is enclosed.

**POLLUTION DISCHARGED TO ENVIRONMENT/UNIT OF OUTPUT**  
(Parameter as specified in the consent issued)

**PART - D**  
**HAZARDOUS WASTES**

(as specified under Hazardous Wastes (Management & Handling Rules, 1989))

Sl. No.	Hazardous Wastes	Total Quantity	
		During the previous financial year (2023-24)	During the current financial year (2024-25)
<b>1) From Process</b>			
a	Used oil	6.069 KL	5.506 KL
b	Oil-soaked cotton waste	0.155 MT	0.239 MT
c	Oil filters	0.272 MT	0.213 MT
d	Discarded containers	3.466 MT	3.323 MT
e	Used batteries	0.096 MT	0.511 MT
f	Other - Paint Residue	Nil	Nil
g	Electrical & Electronic waste	53.638 MT	16.424 MT
h	Bio-medical waste**	9.366 MT	4.563 MT
2	From Pollution Control Facilities	Not Applicable	Not Applicable

**Note:**

\* Since the quantity of hazardous waste being generated at our CISF facility is very low, we have disposed this waste through our main campus along with hazardous waste generated there, hence the manifest form is common for both facilities.

\*\*Biomedical waste includes sanitary waste generated in the campus

**PART - E:**

**SOLID WASTES:**

Sl. No.	Solid Wastes	Total Quantity in MT	
		During the previous financial year (2023-24)	During the current financial year (2024-25)
<b>2) From Process</b>			
a	Paper in MT	17.09	24.52
b	Wood in MT	8.85	9.09
c	Plastic in MT	14.61	10.93
d	Metal in MT	68.36	53.08
e	Glass in MT	5.04	3.52
f	Mixed Waste in MT	71.39	94.97
<b>3) From Pollution Control Facilities</b>			
a	STP Sludge in MT	290.54	416.37

<b>4) Quantity recycled or re-utilized within the unit.</b>			
a	Garden Waste in MT	137.02	143.49
b	Food Waste in MT	243.652	315.85*

Note: Food waste includes coconut shells generated during food preparations

### PART - F

#### CHARACTERISTICS OF HAZARDOUS AS WELL AS SOLID WASTES AND THEIR DISPOSAL PRACTICE

Sl. No.	Type of waste generated	Quantity (FY24-25)	Composition of waste	Method of disposal
<b>Hazardous waste</b>				
1	Used oil	5.506 KL	Liquid	To PCB authorized recycler
2	Oil-soaked cotton waste	0.239 MT	Solid	To PCB authorized disposal facility
3	Oil filters	0.213 MT	Solid	To PCB authorized disposal facility
4	Discarded containers	3.323 MT	Solid	To PCB authorized recycler
5	Used batteries	0.511 MT	Solid	To PCB authorized recycler
6	Electrical and Electronic waste	16.424 MT	Solid	To PCB authorized recycler
7	Bio-medical waste	4.563 MT	Solid	To PCB authorized disposal facility
<b>Solid waste</b>				
8	Paper (carton boxes / tissue paper / shredded paper/ newspaper)	24.52 MT	Solid	To PCB authorized disposal facility
9	Wood (Broken piece/ old furniture / packing materials etc.)	9.09 MT	Solid	To PCB authorized disposal facility
10	Plastic (Used PET bottles/ broken pipes/packing materials etc.)	10.93 MT	Solid	To PCB authorized disposal facility
11	Metal (Rusted iron pipes, rods, spare parts etc.)	53.08 MT	Solid	To PCB authorized disposal facility
12	Glass (broken glass doors, windows, discarded glass wares etc.)	3.52 MT	Solid	To PCB authorized disposal facility
13	Garden waste	143.49 MT	Solid	Inhouse composting and usage
14	Mixed garbage	94.97 MT	Solid	To authorized waste recovery facility
15	Food Waste	315.85 MT	Semi Solid	Treated at in-house biogas plant. Coconut shells are used as firewood.

16	STP Sludge	416.37 MT	Semi-solid	Used as manure in the premise post drying
----	------------	-----------	------------	---

### PART - G

**IMPACT OF THE POLLUTION CONTROL MEASURES TAKEN ON CONSERVATION OF NATURAL RESOURCES AND CONSEQUENTLY ON THE COST OF PRODUCTION**

Not applicable

### PART - H & I

**ADDITIONAL MEASURES/INVESTMENT PROPOSAL FOR ENVIRONMENTAL PROTECTION INCLUDING ABATEMENT OF POLLUTION, PREVENTION OF POLLUTION**

**ANY OTHER PARTICULARS FOR IMPROVING THE QUALITY OF THE ENVIRONMENT**

#### Companywide key updates:

**Infosys Carbon Neutrality:** Since 2008, Infosys has actively pursued its carbon neutral goal by focusing on decarbonization. Our strategy includes reducing our carbon footprint across global operations, transitioning to renewable energy, and offsetting carbon by helping more than 100,000 families in local communities reduce carbon emissions. We achieved Carbon Neutrality in fiscal 2020, 30 years ahead of the 2050 timeline set by the Paris Agreement and we continue to be carbon neutral 6 years in a row.

Our next frontier is to become climate positive in 2030, engineering the path with precision

#### Initiatives at Mysore Development Center:

**Tree Planting:** Tree saplings are being planted in and around the campus to enhance the green cover area. The tree species selected are native to the region and we use organic manure for landscape maintenance. We have planted more than 1.7 lakh tree saplings in and around the campus for enhancing the green cover area.

Following measure have been implemented towards conservation of resources, prevention of pollution and improving the quality of the environment-

- In FY24-25, 94.94% of the electrical energy consumed on the campus is sourced through renewable energy sources, thereby reducing the carbon footprints. 100% of the renewable energy is sourced through Infosys owned PV captive plant.
- Various measures have been implemented towards energy conservation such as consolidation of buildings, power optimization projects through operation controls etc.
- We continue to dispose of mixed waste through waste recovery facilities thereby preventing it by getting into landfills.
- Regular awareness sessions are being conducted on Environmental Protection to trainees, employees, and contractual staffs.
- 100% of the wastewater is recycled across our campuses.

- On occasion of **World Environment Day 2024** following events were organized  
**Mega Tree Planting and Adoption Drive with a theme "Our Land. Our Future. We are #GenerationRestoration"**

Infosys Mysore DC and SOFTEN in association with CII, Mysore Chapter has organized "The Mega Tree Planting and Adoption Drive" and we have planted 5000+ tree saplings at Horse Park, Mounted Police Head Quarters premises.

The formal inauguration of drive was organized on 5<sup>th</sup> June'2024. **Mr. Ramesh Banoth**, IPS, Commissioner of Police, Mysuru was invited as Chief Guest along with **Dr. Basavaraja K N**, IFS, Deputy Conservator of Forest, Mysuru Division. **Mr. Sudhir R**, VP – Global Head, Facilities, Infosys Ltd. spearheaded the tree planting drive along with team of Infosys Employees. Many dignitaries from Department of Police and Forest graced the occasion along with representatives from CII, Mysuru Chapter and SOFTEN (CSR wing of Infosys Mysore Development Center).

The mega plantation drive kick started by planting the tree saplings

3000+ people from Infosys including employees and family, trainees and contractual staffs participated in the collection drive

#### **Lake cleaning drive and tree planting**


Lake cleaning drive is conducted in association with Karnataka State Pollution Control Board, Regional Office, Mysuru and City Municipal Council, Hootagalli

#### **Plastic waste collection drive at Chamundi hills organized by KSPCB**

We participated in plastic waste collection drive organized by KSPCB at Chamundi Hills. Collected plastic waste around temple area & down-to foothills covering 1000 steps with team members from landscaping.

- As part of our CSR, we continue to take care operation and maintenance of 8 MLD STP at Hebbal Lake and maintenance of lake premise as per MoU.
- As part of our ongoing public awareness, we are conducting quarterly waste collection drives in Hebbal Industrial Area. With 350+ staff members and one hour of collection drive we are picking 1.5 to 2 tonnes of waste and being disposed through CMC, Hootagalli.
- Phasing-out R22 (ODS) refrigerant: We are replacing R22 refrigerant based air conditioners and water coolers to non-ODS based units in phased manner.
- Various awareness campaigns were conducted in the campus viz. seedball making drives, poster making, art from waste, road safety etc.

Date: 26.09.2025

  
Authorized Signatory  
Ganapathy CP  
Regional Head - Facilities



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402986, 4282027 Mobile : 9148337866  
 Office : 1030, Geetha Road, Chamarajapuram, Mysuru - 570 005 Telephone : 2402987, 4253825  
 Bengaluru Office : # 895, 2nd B Cross, Hosakera Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : [info@ganeshlaboratory.com](mailto:info@ganeshlaboratory.com), [lab.ganesh@gmail.com](mailto:lab.ganesh@gmail.com) • Web : [www.ganeshlaboratory.com](http://www.ganeshlaboratory.com)

### TEST REPORT

Page 1 of 1

**CUSTOMER ADDRESS,**

M/s. Infosys Limited  
 IL Mysore STP Unit  
 Bid#-8,10-12, Pwll  
 Plot No. 5350-354,388-372 & 376-385  
 Kladb Industrial Area, Hebbal  
 Mysore, Karnataka - 570027, India.

- 1) Sample description : Water
- 2) Sample Marked as : STP Treated Water
- 3) Sampling location : STP - 2
- 4) Sample Package / Quantity: PET Bottle, 1 Liter

Control No	C-04130/2025
Customer Ref	Purchase Order
Date of Sample Collection	10-03-2025
Date of Sample Receipt	10-03-2025
Date of Commencement	11-03-2025
Date of Completion	17-03-2025
Date of Report	18-03-2025
5) Sample Condition:	Satisfactory
6) Sample Code/batch No.	Not Specified
7) Sample Drawn By	Lab Personnel
8) Sampling Protocol:	IS 3025

Sl. No	Test	Unit	Result	KSPCB Limits	Test Method
1	Colour	---	Colourless ✓	Colourless	IS: 3025 (P 4)
2	pH Value	---	7.71 ✓	6.5-9.0	IS: 3025 (P 11)
3	Suspended Solids	mg/l	BLQ(LOQ 2) ✓	Not more than 20	IS: 3025 (P 17)
4	Dissolved solids (Inorganic)	mg/l	484 ✓	2100	IS: 3025 (P 18)
5	Oil & Grease	mg/l	BLQ(LOQ 2) ✓	Not more than 10	IS: 3025 (P 39)
6	Total Residual Chlorine	mg/l	BLQ(LOQ 0.2) ✓	Not Applicable	IS:3025 (P 26)
7	Ammoniacal Nitrogen	mg/l	0.69 ✓	Not more than 5	IS:3025 (P 34)
8	Total Nitrogen	mg/l	5.32 ✓	Not more than 10	IS:3025 (P 34)
9	Biochemical Oxygen Demand (3days @27°C)	mg/l	2 ✓	Not more than 10	IS: 3025 (P 44)
10	Chemical Oxygen Demand	mg/l	15 ✓	Not more than 50	IS: 3025 (P 58)
11	Chloride as Cl	mg/l	117 ✓	600	IS: 3025 (P 32)
12	Phosphorous as P	mg/l	1.24 ✓	Not more than 5	IS: 3025 (P 31)
13	Sulphate as SO <sub>4</sub>	mg/l	44 ✓	1000	IS: 3025 (P 24)

Comments: The test result meets the KSPCB Limits.

\*\*\*End of the Report\*\*\*

*de*  
  
 636110

Reviewed By

*Hanalekha.KH*



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

*de*  
 Authorised Signatory

- NOTE:**
1. The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  2. Total liability of our institute is limited to the invoice amount.
  3. Samples will be disposed after the specified retention period.
  4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  5. Sample (s) or not drawn by us unless otherwise stated.



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402986, 4262027 Mobile : 9148337866  
 Office : 1030, Geseha Road, Chamarajapuram, Mysuru - 570 005 Telephone : 2402987, 4263925  
 Bengaluru Office : # 895, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

### TEST REPORT

**CUSTOMER ADDRESS,**

M/s. Infosys Limited  
 IL Mysore STP Unit  
 Bld 1-8, 10-12, Pwll  
 Plot No. 9850-354, 363-372 & 376-385  
 Kadb Industrial Area, Hebbal  
 Mysore, Karnataka - 570027, India.

- 1) Sample description : Water
- 2) Sample Marked as : STP Treated Water
- 3) Sampling location : STP -2
- 4) Sample Package / Quantity: Sterilized Bottle , 250 ml

Control No	Page 1 of 1
Customer Ref	B-04130/2025
Date of Sample collection	Purchase Order
Date of Sample Receipt	10-03-2025
Date of Commencing	10-03-2025
Date of Completion	11-03-2025
Date of Report	15-03-2025
5) Sample condition:	16-03-2025
6) Sample Code/batch No.	Satisfactory
7) Sample Drawn By	Not Specified
8) Sampling Protocol	Lab Personnel
	IS 1622

Sl. No.	Test	Unit	Result	KSPCB LIMIT	Test Method
1	Faecal Coliforms	MPN/100ml	<2 ✓	< 100	IS 1622:1981
2	E.coli	MPN/100ml	<2 ✓	Absent	IS 1622:1981

Comments: The test result meets the KSPCB limit.

Note: The result <2 is Considered as Absent /100ml.

\*\*\*End of the Report\*\*\*

Reviewed By



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

Authorised Signatory

- NOTE:**
1. The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  2. Total liability of our institute is limited to the Invoice amount.
  3. Samples will be disposed after the specified retention period.
  4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  5. Sample (s) or not drawn by us unless otherwise stated.



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402886, 4282027 Mobile : 9148397866  
Office : 1030, Geetha Road, Chamaraapuram, Mysuru - 570 005 Telephone : 2402987, 4253825  
Bengaluru Office : # 895, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bengaluru - 560 085  
Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

### TEST REPORT

Page 1 of 1

**CUSTOMER ADDRESS.**

M/s. Infosys Limited  
IL Mysore STP Unit  
Bld-1-8, 10-12, Pwll  
Plot No. S350-354, 366-372 & 376-385  
Kadab Industrial Area, Hebbal  
Mysore, Karnataka - 570027, India.

- 1) Sample description : Water
- 2) Sample Marked as : STP Treated Water
- 3) Sampling location : STP - 3
- 4) Sample Package / Quantity: PET Bottle, 1 Liter

Control No	C-04131/2025
Customer Ref	Purchase Order
Date of Sample Collection	10-03-2025
Date of Sample Receipt	10-03-2025
Date of Commencement	11-03-2025
Date of Completion	17-03-2025
Date of Report	18-03-2025
5) Sample Condition:	Satisfactory
6) Sample Code/batch No.	Not Specified
7) Sample Drawn By	Lab Personnel
8) Sampling Protocol	IS 3025

Sl. No	Test	Unit	Result	KSPCB Limits	Test Method
1	Colour	---	Colourless ✓	Colourless	IS: 3025 (P 4)
2	pH Value	---	7.54 ✓	6.5-8.0	IS: 3025 (P 11)
3	Suspended Solids	mg/l	BLQ(LOQ 2) ✓	Not more than 20	IS: 3025 (P 17)
4	Dissolved solids (Inorganic)	mg/l	688 ✓	2100	IS: 3025 (P 16)
5	Oil & Grease	mg/l	BLQ(LOQ 2) ✓	Not more than 10	IS: 3025 (P 39)
6	Total Residual Chlorine	mg/l	BLQ(LOQ 0.2) ✓	Not Applicable	IS: 3025 (P 26)
7	Ammonical Nitrogen	mg/l	0.69 ✓	Not more than 5	IS: 3025 (P 34)
8	Total Nitrogen	mg/l	5.91 ✓	Not more than 10	IS: 3025 (P 34)
9	Biochemical Oxygen Demand (3days @27°C)	mg/l	2 ✓	Not more than 10	IS: 3025 (P 44)
10	Chemical Oxygen Demand	mg/l	15 ✓	Not more than 50	IS: 3025 (P 58)
11	Chloride as Cl	mg/l	147 ✓	500	IS: 3025 (P 32)
12	Phosphorous as P	mg/l	3.14 ✓	Not more than 5	IS: 3025 (P 31)
13	Sulphate as SO <sub>4</sub>	mg/l	42 ✓	1000	IS: 3025 (P 24)

Comments: The test result meets the KSPCB Limits.

\*\*\*End of the Report\*\*\*

Reviewed By

*H. S. Srinivasan*



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

*[Signature]*  
Authorised Signatory

- NOTE:**
1. The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  2. Total liability of our Institute is limited to the invoice amount.
  3. Samples will be disposed after the specified retention period.
  4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  5. Sample (s) or not drawn by us unless otherwise stated.



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 018 Telephone : 2402986, 4282027 Mobile : 9148337866  
 Office : 1030, Geetha Road, Chamaraapuram, Mysuru - 570 005 Telephone : 2402987, 4253825  
 Bengaluru Office : # 895, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

### TEST REPORT

**CUSTOMER ADDRESS,**

M/s. Infosys Limited  
 IL Mysore STP Unit  
 Bld-8, 10-12, Pwiti  
 Plot No. 5350-364, 369-372 & 378-385  
 Kadb Industrial Area, Hebbal  
 Mysore, Karnataka - 570027, India.

- 1) Sample description : Water
- 2) Sample Marked as : STP Treated Water
- 3) Sampling location : STP - 3
- 4) Sample Package / Quantity: Sterilized Bottle , 250 ml

Page 1 of 1

Control No	B-04131/2025
Customer Ref	Purchase Order
Date of Sample collection	10-03-2025
Date of Sample Receipt	10-03-2025
Date of Commencing	11-03-2025
Date of Completion	13-03-2025
Date of Report	18-03-2025
5) Sample condition:	Satisfactory
6) Sample Code/batch No.	Not Specified
7) Sample Drawn By	Lab Personnel
8) Sampling Protocol	IS 1622

Sl. No.	Test	Unit	Result	KSPCB LIMIT	Test Method
1	Faecal Coliforms	MPN/100ml	<2	< 100	IS 1622:1981
2	E.coli	MPN/100ml	<2	Absent	IS 1622:1981

Comments: The test result meets the KSPCB limit.

Note: The result <2 is Considered as Absent /100ml.

\*\*\*End of the Report\*\*\*

Reviewed By



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

Authorized Signatory

- NOTE:**
1. The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  2. Total liability of our institute is limited to the invoice amount.
  3. Samples will be disposed after the specified retention period.
  4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  5. Sample (s) or not drawn by us unless otherwise stated.



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402986, 4282027 Mobile : 9148337866  
 Office : 1030, Geetha Road, Chamaraajapuram, Mysuru - 570 005 Telephone : 2402987, 4253825  
 Bengaluru Office : # 895, 2nd B Cross, Kasakere Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

### TEST REPORT

Page 1 of 1

**CUSTOMER ADDRESS,**  
 M/s. Infosys Ltd.,  
 No. 350, Hebbal Electronic city,  
 Hootagalli,  
 MYSORE - 570 018.

Control No: G-04156/2025  
 Customer reference: Purchase Order  
 Date of report: 17-03-2025

1) Sample description: Flue Gas  
 2) Sampled by : Lab Personnel

3) Date of Sampling: 08-03-2025  
 4) Sampling protocol: IS 11255

Sl. No	General parameters	Details of stack
1	Stack connected to	DG 2000 KVA No.1 (Load 62%)
2	Stack diameter	0.86 m
3	Cross Section area	0.3422 m <sup>2</sup>
4	Ambient Temperature	35°C
5	Flue gas Temperature	253°C
6	Flue gas Velocity	10.16 m/sec
7	Quantity of Flue gas discharges into the atmosphere	6474.69 Nm <sup>3</sup> /hr

Sl. No	Test	Unit	Result	KSPCB Limit	Test method
1	Particulate Matter (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	15.09 ✓	75	IS 11255 (Part-1):1985 (RA 2019)
2	Sulphur dioxide	mg/Nm <sup>3</sup>	23.83 ✓	180	IS 11255 (Part-2):1985 (RA 2019)
3	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	mg/Nm <sup>3</sup>	49.06 ✓	No. Specified	IS 11255 (Part-7) (RA 2022)
4	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	ppmv	28.07 ✓	710	IS 11255 (Part-7) (RA 2022)
5	Carbon monoxide (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	55.84 ✓	150	GCAS/SOP/7.2/SE/CO
6	Non Methane Hydrocarbon (as C at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	15.14 ✓	100	IS 13270:1992 (RA 2019)

Comments: The test result meets the KSPCB standards.

Details of Equipment used for monitoring		Stack Sampler
Make		VAYUBHODAN
Model		VSS-1
SL. No.		255-DTK-2013
Calibration Due Date		09-08-2025

\*\*\*End of the Report\*\*\*

*de*  
*COB*  
 236210

Reviewed By

*[Signature]*



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

*[Signature]*  
 Authorised Signatory

- NOTE:**
- The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  - Total liability of our institute is limited to the invoice amount.
  - Samples will be disposed after the specified retention period.
  - This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  - Sample (s) or not drawn by us unless otherwise stated.



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 018 Telephone : 2402986, 4282027 Mobile : 9148337866  
 Office : 1030, Geetha Road, Chamaraapuram, Mysuru - 570 005 Telephone : 2402987, 4253825  
 Bengaluru Office : # 895, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com Web : www.ganeshlaboratory.com

### TEST REPORT

**CUSTOMER ADDRESS,**

M/s. Infosys Ltd,  
 No. 850, Hebbal Electronic city,  
 Hootagalli,  
 MYSORE - 570 018.

Control No C-04183/2025  
 Customer reference Purchase Order  
 Date of report 17-03-2025

Page 1 of 1

- 1) Sample description: Flue Gas  
 2) Sampled by : Lab Personnel

- 3) Date of Sampling 08-03-2025  
 4) Sampling protocol IS 11255

Sl. No	General parameters	Details of stack
1	Stack connected to	D&S Set 2000 KVA No. 2 (Load 62%)
2	Stack diameter	0.66 m
3	Cross Section area	0.3422 m <sup>2</sup>
4	Ambient Temperature	35°C
5	Flue gas Temperature	247°C
6	Flue gas Velocity	8.18 m/sec
7	Quantity of Flue gas discharges into the atmosphere	5285.37 Nm <sup>3</sup> /hr

Sl. No	Test	Unit	Result	KSPCB Limit	Test method
1	Particulate Matter (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	18.18	75	IS 11255 (Part-1):1985 (RA 2019)
2	Sulphur dioxide	mg/Nm <sup>3</sup>	25.79	100	IS 11255 (Part-2):1985 (RA 2019)
3	Oxides of Nitrogen (at 15% O <sub>2</sub> dry basis)	mg/Nm <sup>3</sup>	45.48	Not Specified	IS 11255 (Part-7) (RA 2022)
4	Oxides of Nitrogen (at 15% O <sub>2</sub> dry basis)	ppmv	24.10	710	IS 11255 (Part-7) (RA 2022)
5	Carbon monoxide (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	65.74	150	GCAS/SOP/7.2/SE/CO
6	Non Methane Hydrocarbon (as C at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	18.84	100	IS 13270:1992 (RA 2019)

Comments: The test result meets the KSPCB standards.

Details of Equipment used for monitoring	
Make	Stack Sampler
Model	VAYUBHODAN
Sl. No.	VSS-1
Calibration Due Date	255-DTK-2013
	09-08-2025

\*\*\*End of the Report\*\*\*

Reviewed By

*[Signature]*



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

*[Signature]*

Authorised Signatory

- NOTE: 1. The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.  
 2. Total liability of our institute is limited to the Invoice amount.  
 3. Samples will be disposed after the specified retention period.  
 4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.  
 5. Sample (s) or not drawn by us unless otherwise stated.



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402986, 4282027 Mobile : 9145337866  
 Office : 1030, Geetha Road, ChamaraJapuram, Mysuru - 570 005 Telephone : 2402987, 4253825  
 Bengaluru Office : # 895, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

### TEST REPORT

Page 1 of 1

**CUSTOMER ADDRESS,**  
 M/s. Infosys Ltd,  
 No. 850, Hebbal Electronic city,  
 Hebbal,  
 MYSORE - 570 018.

Control No C-04154/2025  
 Customer reference Purchase Order  
 Date of report 17-03-2025

1) Sample description: Flue Gas  
 2) Sampled by : Lab Personnel

3) Date of Sampling 08-03-2025  
 4) Sampling protocol IS 11255

Sl. No.	General parameters	Details of stack
1	Stack connected to	DG Set 2000 KVA No. 3 (Load 62%)
2	Stack diameter	0.66 m
3	Cross Section area	0.3422 m <sup>2</sup>
4	Ambient Temperature	35 °C
5	Flue gas Temperature	246 °C
6	Flue gas Velocity	10.02 m/sec
7	Quantity of Flue gas discharges into the atmosphere	6237.78 Nm <sup>3</sup> /hr

Sl. No.	Test	Unit	Result	KSPCB Limit	Test method
1	Particulate Matter (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	21.11	75	IS 11255 (Part-1):1985 (RA 2019)
2	Sulphur dioxide	mg/Nm <sup>3</sup>	23.66	100	IS 11255 (Part-2):1985 (RA 2019)
3	Oxides of Nitrogen (at 16% O <sub>2</sub> , dry basis)	mg/Nm <sup>3</sup>	48.80	Not Specified	IS 11255 (Part-7) (RA 2022)
4	Oxides of Nitrogen (at 16% O <sub>2</sub> , dry basis)	ppmv	24.87	710	IS 11255 (Part-7) (RA 2022)
5	Carbon monoxide (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	63.34	150	GCAS/SOP/7.2/SE/CO
6	Non Methane Hydrocarbon (as C at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	17.14	100	IS 13270:1992 (RA 2019)

Comments: The test result meets the KSPCB standards.

Details of Equipment used for monitoring	Stack Sampler
Make	VAYUBHODAN
Model	VSS-1
Sl. No.	255-DTK-2013
Calibration Due Date	09-08-2025

\*\*\*End of the Report\*\*\*

Reviewed By



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

Authorised Signatory

- NOTE:**
- The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  - Total liability of our institute is limited to the invoice amount.
  - Samples will be disposed after the specified retention period.
  - This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  - Sample (s) or not drawn by us unless otherwise stated.



# Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 018 Telephone : 2402986, 4282027 Mobile : 9148337866  
 Office : 1030, Geetha Road, ChamaraJapuram, Mysuru - 570 006 Telephone : 2402987, 4253825  
 Bengaluru Office : # 895, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bangalore - 560 085  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

## TEST REPORT

**CUSTOMER ADDRESS,**  
 M/s. Infosys Ltd.,  
 No. 35D, Hebbal Electronic city,  
 Hootagalli,  
 MYSORE - 570 018.

Page 1 of 1  
 Control No G-04165/2025  
 Customer reference Purchase Order  
 Date of report 17-03-2025

1) Sample description: Flue Gas  
 2) Sampled by : Lab Personnel

3) Date of Sampling 08-08-2025  
 4) Sampling protocol IS 11255

Sl. No	General parameters	Details of stack
1	Stack connected to	DG Set 2000 KVA No. 4 (Load 62%)
2	Stack diameter	0.66 m
3	Cross Section area	0.3422 m <sup>2</sup>
4	Ambient Temperature	35°C
5	Flue gas Temperature	270 °C
6	Flue gas Velocity	10.48 m/sec
7	Quantity of Flue gas discharges into the atmosphere	6480.62 Nm <sup>3</sup> /hr

Sl. No	Test	Unit	Result	KSPCB Limit	Test method
1	Particulate Matter (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	19.91	75	IS 11255 (Part-1):1985 (RA 2019)
2	Sulphur dioxide	mg/Nm <sup>3</sup>	28.51	100	IS 11255 (Part-2):1985 (RA 2019)
3	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	mg/Nm <sup>3</sup>	48.45	Not Specified	IS 11255 (Part-7) (RA 2022)
4	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	ppmv	23.09	710	IS 11255 (Part-7) (RA 2022)
5	Carbon monoxide (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	43.14	150	GCAS/SOP/7.2/SE/CO
6	Non Methane Hydrocarbon (as C at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	17.54	100	IS 13270:1992 (RA 2019)

Comments: The test result meets the KSPCB standards.

Details of Equipment used for monitoring	
Make	Stack Sampler
Model	VAYUBHODAN
Sl. No.	VSS-1
Calibration Due Date	285-DTK-2013
	09-08-2025

\*\*\*End of the Report\*\*\*

Reviewed By

*[Signature]*



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

*[Signature]*

Authorised Signatory

- NOTE: 1. The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.  
 2. Total liability of our institute is limited to the invoice amount.  
 3. Samples will be disposed after the specified retention period.  
 4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.  
 5. Sample (s) or not drawn by us unless otherwise stated.



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402986, 4282027 Mobile : 9148337866  
 Office : 1030, Geetha Road, Chamarajapuram, Mysuru - 570 005 Telephone : 2402987, 4253825  
 Bengaluru Office : # 895, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

### TEST REPORT

Page 1 of 1

**CUSTOMER ADDRESS,**  
 M/s. Infosys Ltd.,  
 No. 350, Hebbal Electronic city,  
 Hootagalli,  
 MYSORE - 570 018.

Control No C-04166/2025  
 Customer reference Purchase Order  
 Date of report 17-03-2025

1) Sample description: Flue Gas  
 2) Sampled by : Lab Personnel

3) Date of Sampling 08-03-2025  
 4) Sampling protocol IS-11255

Sl.No	General parameters	Details of stack
1	Stack connected to	DG Set 2000 KVA No. 5 (Load 82%)
2	Stack diameter	0.66 m
3	Cross Section area	0.3422 m <sup>2</sup>
4	Ambient Temperature	35°C
5	Flue gas Temperature	276°C
6	Flue gas Velocity	10.21 m/sec
7	Quantity of Flue gas discharges into the atmosphere	5916.78 Nm <sup>3</sup> /hr

Sl. No	Test	Unit	Result	KSPCB Limit	Test method
1	Particulate Matter (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	20.71	75	IS 11255 (Part-1):1985 (RA 2019)
2	Sulphur dioxide	mg/Nm <sup>3</sup>	30.13	100	IS 11255 (Part-2):1985 (RA 2019)
3	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	mg/Nm <sup>3</sup>	47.24	Not Specified	IS 11255 (Part-7) (RA 2022)
4	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	ppmv	25.11	710	IS 11255 (Part-7) (RA 2022)
5	Carbon monoxide (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	63.98	150	GCAS/SOP/7.2/SE/CO
6	Non Methane Hydrocarbon (as C at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	18.21	100	IS 13270:1992 (RA 2019)

Comments: The test result meets the KSPCB standards.

Details of Equipment used for monitoring		Stack Sampler
Make		VAYUBHODAN
Model		VSS-1
SL. No.		255-DTK-2013
Calibration Due Date		09-08-2025

\*\*\*End of the Report\*\*\*

Reviewed By



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

Authorized Signatory

- NOTE:**
- The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  - Total liability of our institute is limited to the Invoice amount.
  - Samples will be disposed after the specified retention period.
  - This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  - Sample (s) or not drawn by us unless otherwise stated.



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402986, 4282027 Mobile : 9145337666  
 Office : 1030, Geetha Road, Chamaraajapuram, Mysuru - 570 005 Telephone : 2402987, 4253325  
 Bengaluru Office : # 895, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

### TEST REPORT

**CUSTOMER ADDRESS,**

M/s. Infosys Ltd.,  
No. 350, Hebbal Electronic city,  
Hootagali,  
MYSORE - 570 018.

Page 1 of 1  
Control No C-04169/2025  
Customer reference Purchase Order  
Date of report 17-03-2025

- 1) Sample description: Flue Gas  
2) Sampled by : Lab Personnel

- 3) Date of Sampling 08-03-2025  
4) Sampling protocol IS 11255

Sl. No	General parameters	Details of stack
1	Stack connected to	DG Set 2270 KVA No. 1 (Load 38%)
2	Stack diameter	1.10 m
3	Cross Section area	0.9507 m <sup>2</sup>
4	Ambient Temperature	34 °C
5	Flue gas Temperature	209 °C
6	Flue gas Velocity	7.90 m/sec
7	Quantity of Flue gas discharges into the atmosphere	15279.58 Nm <sup>3</sup> /hr

Sl. No	Test	Unit	Result	KSPCB Limit	Test method
1	Particulate Matter (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	31.11 ✓	75	IS 11255 (Part-1):1995 (RA 2019)
2	Sulphur dioxide	mg/Nm <sup>3</sup>	16.74 ✓	100	IS 11255 (Part-2):1995 (RA 2019)
3	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	mg/Nm <sup>3</sup>	43.02 ✓	Not Specified	IS 11255 (Part-7) (RA 2022)
4	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	ppmv	22.66 ✓	710	IS 11255 (Part-7) (RA 2022)
5	Carbon monoxide (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	92.28 ✓	150	GCAS/SOP/7 2/SE/CO.
6	Non Methane Hydrocarbon (as C at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	24.73 ✓	100	IS 13270:1992 (RA 2019)

**Comment:** The test result meets the KSPCB standards.

Details of Equipment used for monitoring		Stack Sampler
Make	ECOTECH	
Model	ESS-100	
SL. No.	21-K-360	
Calibration Due Date	19-12-2025	

\*\*\*End of the Report\*\*\*

*OK*  
**CONF**  
630210

Reviewed By

*[Signature]*



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

*[Signature]*  
**Authorised Signatory**

- NOTE:**
1. The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  2. Total liability of our institute is limited to the invoice amount.
  3. Samples will be disposed after the specified retention period.
  4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  5. Sample (s) or not drawn by us unless otherwise stated.



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402986, 4282027 Mobile : 9148337866  
 Office : 1030, Geetha Road, Chamaraajapuram, Mysuru - 570 005 Telephone : 2402987, 4253825  
 Bengaluru Office : # 895, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bengaluru - 560 065  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

### TEST REPORT

**CUSTOMER ADDRESS,**

M/s. Infosys Ltd.,  
No. 350, Hebbal Electronic city,  
Hootagalli,  
MYSORE - 570 018.

Page 1 of 1  
Control No C-04160/2025  
Customer reference Purchase Order  
Date of report 17-03-2025

1) Sample description: Flue Gas  
2) Sampled by : Lab Personnel

3) Date of Sampling 08-03-2025  
4) Sampling protocol IS-11256

Sl.No	General parameters	Details of stack
1	Stack connected to	DG Set 2270 KVA No. 2 (Load 38%)
2	Stack diameter	1.10m
3	Cross Section area	0.8506 m <sup>2</sup>
4	Ambient Temperature	34°C
5	Flue gas Temperature	214 °C
6	Flue gas Velocity	8.30 m/sec
7	Quantity of Flue-gas discharges into the atmosphere	15887.96 Nm <sup>3</sup> /hr

Sl. No	Test	Unit	Result	KSPCB Limit	Test method
1	Particulate Matter (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	28.91	75	IS 11255 (Part-1):1985 (RA 2019)
2	Sulphur dioxide	mg/Nm <sup>3</sup>	16.76	100	IS 11255 (Part-2): 1985 (RA 2019)
3	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	mg/Nm <sup>3</sup>	44.77	Not Specified	IS 11255 (Part-7) (RA 2022)
4	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	ppmv	23.79	710	IS 11255 (Part-7) (RA 2022)
5	Carbon monoxide (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	87.84	150	GCAS/SOP/7.2/ISE/CO
6	Non Methane Hydrocarbon (as C at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	23.31	100	IS 13270:1992 (RA 2019)

Comments: The test result meets the KSPCB standards.

Details of Equipment used for monitoring	
Make	Stack Sampler ECOTECH
Model	ESS-100
SL. No.	21-K-360
Calibration Due Date	19-12-2025

\*\*\*End of the Report\*\*\*

Reviewed By

*Blaney*



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

*[Signature]*

Authorised Signatory

- NOTE:**
1. The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  2. Total liability of our institute is limited to the invoice amount.
  3. Samples will be disposed after the specified retention period.
  4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  5. Sample (s) or not drawn by us unless otherwise stated.



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 018 Telephone : 2402988, 4282027 Mobile : 9148337886  
 Office : 1030, Geetha Road, Chamaraipuram, Mysuru - 570 005 Telephone : 2402987, 4253825  
 Bengaluru Office : # 695, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : info@geneshlaboratory.com, lab.ganesh@gmail.com • Web : www.geneshlaboratory.com

### TEST REPORT

**CUSTOMER ADDRESS,**  
 M/s. Infosys Ltd.,  
 No. 350, Hebbal Electronic city,  
 Hootagalli,  
 MYSORE - 570 018.

Page 1 of 1  
 Control No C-04151/2025  
 Customer reference Purchase Order  
 Date of report 17-03-2025

1) Sample description: Flue Gas  
 2) Sampled by : Lab Personnel

3) Date of Sampling 08-03-2025  
 4) Sampling protocol IS 11255

Sl. No	General parameters	Details of stack
1	Stack connected to	DG Set 2270 KVA No. 3 (Load 38%)
2	Stack diameter	1.10 m
3	Cross Section area	0.9808 m <sup>2</sup>
4	Ambient Temperature	34 °C
5	Flue gas Temperature	218 °C
6	Flue gas Velocity	8.55 m/sec
7	Quantity of Flue gas discharges into the atmosphere	18233.18 Nm <sup>3</sup> /hr

Sl. No	Test	Unit	Result	KSPCB Limit	Test method
1	Particulate Matter (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	29.55	75	IS 11255 (Part-1):1985 (RA 2019)
2	Sulphur dioxide	mg/Nm <sup>3</sup>	25.04	100	IS 11255 (Part-2):1985 (RA 2019)
3	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	mg/Nm <sup>3</sup>	47.41	Not Specified	IS 11255 (Part-7) (RA 2022)
4	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	ppmv	25.19	710	IS 11255 (Part-7) (RA 2022)
5	Carbon monoxide (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	82.73	150	GCAS/SOP/7.2/SE/CO
6	Non Methane Hydrocarbon (as C at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	21.54	100	IS 13270:1992 (RA 2019)

Comments: The test result meets the KSPCB standards.

Details of Equipment used for monitoring	Stack Samplet
Make	ECOTECH
Model	ESS-100
SL. No.	21-K-360
Calibration Due Date	19-12-2025

\*\*\*End of the Report\*\*\*

Reviewed By

*[Signature]*



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

*[Signature]*  
 Authorised Signatory

- NOTE :**
1. The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  2. Total liability of our institute is limited to the invoice amount.
  3. Samples will be disposed after the specified retention period.
  4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  5. Sample (s) or not drawn by us unless otherwise stated.



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402936, 4282027 Mobile : 9148337886  
 Office : 1030, Geetha Road, Chamaraapuram, Mysuru - 570 005 Telephone : 2402987, 4253825  
 Bengaluru Office : # 895, 2nd B Cross, Hosakera Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

### TEST REPORT

Page 1 of 1

**CUSTOMER ADDRESS,**  
 M/s. Infosys Ltd.,  
 No. 350, Hebbal Electronic City,  
 Hootagalli,  
 MYSORE - 570 018.

Control No                    **G-04157/2025**  
 Customer reference        **Purchase Order**  
 Date of report              **17-03-2025**

1) Sample description: Flue Gas  
 2) Sampled by                : Lab Personnel

3) Date of Sampling        **08-03-2025**  
 4) Sampling protocol       **IS 11255**

Sl. No	General parameters	Details of stack
1	Stack connected to	DG 3025 KVA NO.1 (Load 48%)
2	Stack diameter	1.25 m
3	Gross Section area	1.2276 m <sup>2</sup>
4	Ambient Temperature	34 °C
5	Flue gas Temperature	247 °C
6	Flue gas Velocity	8.57 m/sec
7	Quantity of Flue gas discharges into the atmosphere	19840.63 Nm <sup>3</sup> /hr

Sl. No	Test	Unit	Result	KSPCB Limit	Test method
1	Particulate Matter (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	25.73	75	IS 11255 (Part-1):1985 (RA 2019)
2	Sulphur dioxide	mg/Nm <sup>3</sup>	25.90	100	IS 11255 (Part-2):1985 (RA 2019)
3	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	mg/Nm <sup>3</sup>	45.38	Not Specified	IS 11255 (Part-7) (RA 2022)
4	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	ppmv	24.12	710	IS 11255 (Part-7) (RA 2022)
5	Carbon monoxide (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	55.14	150	GCAS/SOP/7.2/SE/CO
6	Non Methane Hydrocarbon (as C at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	15.84	100	IS 13270:1992 (RA 2019)

Comments: The test result meets the KSPCB standards.

Details of Equipment used for monitoring	Stack Sampler
Make	ECOTECH
Model	ESS-100
SL. No.	21-K-360
Calibration Due Date	19-12-2025

\*\*\*End of the Report\*\*\*

Ok  
  
 636210

Reviewed By



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

Authorised Signatory



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402986, 4282027 Mobile : 9148337866  
 Office : 1030, Geeltra Road, Chamarejapuram, Mysuru - 570 085 Telephone : 2402987, 4253825  
 Bengaluru Office : # 695, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

### TEST REPORT

**CUSTOMER ADDRESS,**  
 M/s. Infosys Ltd.,  
 No. 36D, Hebbal Electronic city,  
 Hootagalli,  
 MYSORE - 570 018.

Page 1 of 1

Control No                    **C-04158/2025**  
 Customer reference        **Purchase Order**  
 Date of report              **17-03-2025**

1) Sample description: Flue Gas  
 2) Sampled by                : Lab Personnel

3) Date of Sampling        **08-03-2025**  
 4) Sampling protocol      **IS 11255**

Sl. No	General parameters	Details of stack
1	Stack connected to	DG 3025 KVA NO.2 (Load 48%)
2	Stack diameter	1.25m
3	Cross Section area	1.2276 m <sup>2</sup>
4	Ambient Temperature	34 °C
5	Flue gas Temperature	251 °C
6	Flue gas Velocity	8.84 m/sec
7	Quantity of Flue gas discharges into the atmosphere	20309.20 Nm <sup>3</sup> /hr

Sl. No	Test	Unit	Result	KSPCB Limit	Test method
1	Particulate Matter (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	27.21	75	IS 11255 (Part-1):1985 (RA 2019)
2	Sulphur dioxide	mg/Nm <sup>3</sup>	22.33	100	IS 11255 (Part-2):1985 (RA 2019)
3	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	mg/Nm <sup>3</sup>	51.34	Not Specified	IS 11255 (Part-7) (RA 2022)
4	Oxides of Nitrogen (at 15% O <sub>2</sub> , dry basis)	ppmv	27.28	710	IS 11255 (Part-7) (RA 2022)
5	Carbon monoxide (at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	65.31	150	GCAS/SOP/7.2/SE/CO
6	Non Methane Hydrocarbon (as C at 15% O <sub>2</sub> )	mg/Nm <sup>3</sup>	18.28	100	IS 13270:1992 (RA 2019)

Comments: The test result meets the KSPCB standards.

Details of Equipment used for monitoring	
Make	Stack Sampler ECOTECH
Model	ESS-100
SL. No.	21-K-360
Calibration Due Date	18-12-2025

\*\*\*End of the Report\*\*\*

Reviewed By

*[Signature]*



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

*[Signature]*

Authorised Signatory



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402988, 4282027 Mobile : 9148337868  
 Office : 1030, Geetha Road, Chamaraapuram, Mysuru - 570 005 Telephone : 2402987, 4253825  
 Bengaluru Office : # 895, 2nd B Cross, Hosakere Halli, BSJK 3rd Stage, Bengaluru - 560 085  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

### TEST REPORT

**CUSTOMER ADDRESS,**  
 M/s. Infosys Ltd.,  
 No. 350, Hebbal Electronic city,  
 Hootagalli,  
 MYSORE - 570 018.

Page 1 of 1  
 Control No C-04185/2025  
 Customer reference Purchase Order  
 Date of report 19-03-2025

- 1) Sample description : Ambient Air
- 2) Sampling location: SDB-1 Opposite Parking Area
- 3) Sampled by : Lab Personnel

- 4) Date of sampling 10-03-2025 to 11-03-2025
- 5) Duration of sampling 24Hrs
- 6) Sampling protocol IS 5182

Sl. No	Test	Unit	Result	NAAQ Standards	Test Method
1	Sulphur Dioxide (SO <sub>2</sub> ) - 24 hours	µg/m <sup>3</sup>	6.04	80	IS 5182 P-2:2001 (RA:2022)
2	Oxides of Nitrogen as NO <sub>2</sub> - 24 hours	µg/m <sup>3</sup>	34.80	80	IS 5182 P-6:2006 (RA:2022)
3	Particulate Matter (Size < 10µm or PM 10 µg/m <sup>3</sup> ) - 24 hours	µg/m <sup>3</sup>	46.28	100	IS 5182 P-23:2006 (RA:2022)
4	Particulate Matter (Size < 2.5µm or PM 2.5 µg/m <sup>3</sup> ) - 24 hours	µg/m <sup>3</sup>	20.62	60	IS 5182 P-24:2024
5	Ozone (O <sub>3</sub> ) > 8 hours	µg/m <sup>3</sup>	BLQ (LOQ: 0.01)	100	GCAS/SOP/7.2/AA/O3
6	Lead - 24 hours	µg/m <sup>3</sup>	BLQ (LOQ: 0.001)	1	GCAS/SOP/7.2/AA/Pb
7	Carbon Monoxide (CO) - 8 hours	mg/m <sup>3</sup>	BLQ (LOQ: 1.10)	2	IS 5182 P-10 :1999(RA:2019)
8	Ammonia (NH <sub>3</sub> )-24 hours	µg/m <sup>3</sup>	BLQ (LOQ: 1.0)	400	IS 5182 P-25:2018
9	Benzene -Annual	µg/m <sup>3</sup>	BLQ (LOQ: 0.01)	5	IS 5182 P-11:2006 (RA:2022)
10	Benzo (a) Pyrene (BaP)- particulate phase only -Annual	ng/m <sup>3</sup>	BLQ (LOQ: 0.01)	1	GCAS/SOP/7.2/AA/BaP
11	Arsenic -Annual	ng/m <sup>3</sup>	BLQ (LOQ: 1.0)	6	GCAS/SOP/7.2/AA/As
12	Nickel (Ni)- Annual	ng/m <sup>3</sup>	BLQ (LOQ: 1.0)	20	GCAS/SOP/7.2/AA/Ni

Note: NAAQ: The National Ambient Air Quality Standards.  
 BLQ: Below Limit of Quantification, LOQ: Limit of Quantification  
 Comments: The result meets the NAAQ standards for the tested parameters.

Details of Equipment used for monitoring		
Model	AAS 217 BL	AAS 127
SL. No.	17-E-549	15-Q-365
Calibration Due Date	09-08-2025	09-08-2025

BL  
 CO<sub>2</sub>  
 631210

\*\*\*End of the Report\*\*\*

Reviewed By

*[Signature]*



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

*[Signature]*  
 Authorised Signatory

- NOTE :**
1. The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  2. Total liability of our institute is limited to the invoice amount.
  3. Samples will be disposed after the specified retention period.
  4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  5. Sample (s) or not drawn by us unless otherwise stated.



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402966, 4282027 Mobile : 9148337866  
 Office : 1030, Geetha Road, Chamaraapuram, Mysuru - 570 005 Telephone : 2402987, 4253325  
 Bengaluru Office : # 895, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

### TEST REPORT

**CUSTOMER ADDRESS,**

M/s. Infosys Ltd.,  
 No. 350, Hebbal Electronic city,  
 Hootagalli,  
 MYSORE - 570 018.

Control No  
 Customer reference  
 Date of report

Page 1 of 1  
 C-04187/2025  
 Purchase Order  
 19-03-2025

- 1) Sample description : Ambient Air  
 2) Sampling location: Between Lake 10 & Forest Area Road  
 3) Sampled by : Lab Personnel

- 4) Date of sampling 10-03-2025 to 11-03-2025  
 5) Duration of sampling 24Hrs.  
 6) Sampling protocol IS 5182

Sl. No	Test	Unit	Result	NAAQ Standards	Test Method
1	Sulphur Dioxide (SO <sub>2</sub> ) - 24 hours	µg/m <sup>3</sup>	6.71	80	IS 5182 P-2:2001 (RA:2022)
2	Oxides of Nitrogen as NO <sub>2</sub> - 24 hours	µg/m <sup>3</sup>	35.04	80	IS 5182 P-8:2005 (RA:2022)
3	Particulate Matter (Size < 10µm or PM 10 µg/m <sup>3</sup> ) - 24 hours	µg/m <sup>3</sup>	42.65	100	IS 5182 P-23:2008 (RA:2022)
4	Particulate Matter (Size < 2.5µm or PM 2.5 µg/m <sup>3</sup> ) - 24 hours	µg/m <sup>3</sup>	18.87	60	IS 5192 P-24:2024
5	Ozone (O <sub>3</sub> ) - 8 hours	µg/m <sup>3</sup>	BLQ (LOQ: 6.01)	100	GCAS/SOP/7.2/AA/O3
6	Lead - 24 hours	µg/m <sup>3</sup>	BLQ (LOQ: 0.001)	1	GCAS/SOP/7.2/AA/M
7	Carbon Monoxide (CO) - 8 hours	mg/m <sup>3</sup>	BLQ (LOQ:1.10)	2	IS 5182 P-10 :1999(RA:2019)
8	Ammonia (NH <sub>3</sub> )-24 hours	µg/m <sup>3</sup>	BLQ (LOQ:1.0)	400	IS 5182 P-25:2018
9	Benzene -Annual	µg/m <sup>3</sup>	BLQ (LOQ: 0.01)	5	IS 5182 P-11:2008 (RA:2022)
10	Benzo (a) Pyrene (BaP) - particulate phase only -Annual	ng/m <sup>3</sup>	BLQ (LOQ: 0.01)	1	GCAS/SOP/7.2/AA/BaP
11	Arsenic -Annual	ng/m <sup>3</sup>	BLQ (LOQ: 1.0)	5	GCAS/SOP/7.2/AA/M
12	Nickel (NI)- Annual	ng/m <sup>3</sup>	BLQ (LOQ: 1.0)	20	GCAS/SOP/7.2/AA/M

Note: NAAQ: The National Ambient Air Quality Standards.  
 BLQ: Below Limit of Quantification, LOQ: Limit of Quantification  
 Comments: The result meets the NAAQ standards for the tested parameters.

Details of Equipment used for monitoring		
Model	AAS 217 BL	AAS 127
SL No.	15-H-275	15-G-399
Calibration Due Date	18-12-2025	09-08-2025

\*\*\*End of the Report\*\*\*

Reviewed By

*[Signature]*



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

*[Signature]*

Authorised Signatory

- NOTE:**
1. The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  2. Total liability of our institute is limited to the Invoice amount.
  3. Samples will be disposed after the specified retention period.
  4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  5. Sample (s) or not drawn by us unless otherwise stated.



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402986, 4282027 Mobile : 914837866  
 Office : 1030, Geetha Road, Chamarejapuram, Mysuru - 570 005 Telephone : 2402987, 4253825  
 Bengaluru Office : # 895, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

### TEST REPORT

**CUSTOMER ADDRESS,**

M/s. Infosys Ltd,  
No. 350, Hebbal Electronic city,  
Hootagalli,  
MYSORE - 570 015.

Control No  
Customer reference  
Date of report

Page 1 of 1  
C-04186/2025  
Purchase Order  
18-03-2025

- 1) Sample description : Ambient Air
- 2) Sampling location: HF Building No. 77 & 78 Area.
- 3) Sampled by : Lab Personnel

- 4) Date of sampling 10-03-2025 to 11-03-2025
- 5) Duration of sampling 24Hrs.
- 6) Sampling protocol IS 5182

Sl. No	Test	Unit	Result	NAAQ Standards	Test Method
1	Sulphur Dioxide (SO <sub>2</sub> ) - 24 hours	µg/m <sup>3</sup>	5.66	60	IS 5182 P-2:2001 (RA:2022)
2	Oxides of Nitrogen as NO <sub>2</sub> - 24 hours	µg/m <sup>3</sup>	33.37	60	IS 5182 P-6:2006 (RA:2022)
3	Particulate Matter (Size > 10µm or PM 10 µg/m <sup>3</sup> ) - 24 hours	µg/m <sup>3</sup>	41.67	100	IS 5182 P-23:2006 (RA:2022)
4	Particulate Matter (Size < 2.5µm or PM 2.5 µg/m <sup>3</sup> ) - 24 hours	µg/m <sup>3</sup>	19.26	60	IS 5182 P-24:2024
5	Ozone (O <sub>3</sub> ) - 8 hours	µg/m <sup>3</sup>	BLQ (LOQ: 0.01)	100	GCAS/SOP/7.2/AA/O3
6	Lead - 24 hours	µg/m <sup>3</sup>	BLQ (LOQ: 0.001)	1	GCAS/SOP/7.2/AA/PM
7	Carbon Monoxide (CO) - 8 hours	mg/m <sup>3</sup>	BLQ (LOQ: 1.10)	2	IS 5182 P-10 :1999(RA:2019)
8	Ammonia (NH <sub>3</sub> )-24 hours	µg/m <sup>3</sup>	BLQ (LOQ: 1.0)	400	IS 5182 P-25:2016
9	Benzene -Annual	µg/m <sup>3</sup>	BLQ (LOQ: 0.01)	5	IS 5182 P-11:2006 (RA:2022)
10	Benzo (a) Pyrene (BaP) - particulate phase only -Annual	ng/m <sup>3</sup>	BLQ (LOQ: 0.01)	1	GCAS/SOP/7.2/AA/BaP
11	Arsenic -Annual	ng/m <sup>3</sup>	BLQ (LOQ: 1.0)	6	GCAS/SOP/7.2/AA/PM
12	Nickel (Ni) - Annual	ng/m <sup>3</sup>	BLQ (LOQ: 1.0)	20	GCAS/SOP/7.2/AA/PM

Note: NAAQ: The National Ambient Air Quality Standards.  
BLQ: Below Limit of Quantification, LOQ: Limit of Quantification  
Comments: The result meets the NAAQ standards for the tested parameters.

Details of Equipment used for monitoring		
Model	APM 480 BL	AAS 127
SL. No.	1922-DTB-2011	17-P-738
Calibration Due Date	09-08-2025	09-08-2025

\*\*\*End of the Report\*\*\*

Reviewed By



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

Authorized Signatory

- NOTE :**
1. The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  2. Total liability of our institute is limited to the invoice amount.
  3. Samples will be disposed after the specified retention period.
  4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  5. Sample (s) or not drawn by us unless otherwise stated.



**Ganesh Consultancy & Analytical Services  
(OPC) Private Limited**

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402986, 4282027 Mobile : 9148337868  
 Office : 1030, Geetha Road, Chamarajapuram, Mysuru - 570 005 Telephone : 2402987, 4253825  
 Bengaluru Office : # 895, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

**TEST REPORT**

**AMBIENT NOISE LEVEL MONITORING REPORT**

- |                                    |  |
|------------------------------------|--|
| 1. Name of the Company             | INFOSYS LTD. HEBBAL INDUSTRIAL AREA, MYSORE - 570 018. |
| 2. Sample Collected by             | Lab. Personnel   |
| 3. Date of Collection              | 11-03-2025 - 06:00 AM to 12-03-2025 05:59 AM           |
| 4. Particulars of Sample Collected | Ambient Noise Level Monitoring                         |
| 5. Date of Sample Receipt          | 12-03-2025   |
| 6. Sample Number                   | C-04190  |
| 7. Method Adopted                  | IS:4758:1968 RA:2002                                   |

Sample Location	Day Time Noise Level (PCB Limit)	Day time Noise Level (Monitored value 6 AM to 10 PM)			Night Time Noise Level (PCB Limit)	Night time Noise Level (Monitored value 10 PM to 6 AM)		
		Max.	Min.	Leq In dB(A)		Max.	Min.	Leq In dB(A)
Between lake 10 & Forest Area	65 dB(A)	78.3	41.0	48.3	55 dB(A)	62.6	37.7	40.8

- Note :**
- Day Time is reckoned between 6 A.M and 10 P.M
  - Night Time is reckoned between 10 P.M and 6 A.M
  - Leq: It is energy mean of the noise level over a specified period.
  - \*dB (A) Leq denotes the time weighted average of the level of sound in decibels on scale A which is referable to human hearing.
  - A 'decibel' is a unit in which noise is measured.
  - 'A', in dB (A) Leq, denotes the frequency weighting in the measurement of noise and corresponds to Frequency response characteristics of the human ear.

<b>REMARKS</b>	As per CPCB Standards, Report Status - The measured values for the above Locations are within the standards.
----------------	--

\*\*\*End of Report\*\*\*

Reviewed By

*[Signature]*



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

*[Signature]*

Authorised Signatory

- NOTE :**
- The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  - Total liability of our institute is limited to the invoice amount.
  - Samples will be disposed after the specified retention period.
  - This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  - Sample (s) or not drawn by us unless otherwise stated.



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402986, 4282027 Mobile : 9140337866  
 Office : 1030, Geeltha Road, Chamaraapuram, Mysuru - 570 005 Telephone : 2402987, 4253825  
 Bengaluru Office : # 885, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : info@ganeshlaboratory.com, lab.ganesh@gmail.com • Web : www.ganeshlaboratory.com

### TEST REPORT

#### AMBIENT NOISE LEVEL MONITORING REPORT

- |                                    |  |
|------------------------------------|--|
| 1. Name of the Company             | INFOSYS LTD. HEBBAL INDUSTRIAL AREA, MYSORE - 570 018. |
| 2. Sample Collected by             | Lab. Personnel   |
| 3. Date of Collection              | 11-03-2025 - 06:00 AM to 12-03-2025 05:59 AM           |
| 4. Particulars of Sample Collected | Ambient Noise Level Monitoring                         |
| 5. Date of Sample Receipt          | 12-03-2025   |
| 6. Sample Number                   | C-04189  |
| 7. Method Adopted                  | IS:4758:1968 RA:2002                                   |

Sample Location	Day Time Noise Level (PCB Limit)	Day time Noise Level (Monitored value 6 AM to 10 PM)			Night Time Noise Level (PCB Limit)	Night time Noise Level (Monitored value 10 PM to 6 AM)		
		Max.	Min.	Leq in dB(A)		Max.	Min.	Leq in dB(A)
Opposite SDB-1 parking Area	85 dB(A)	91.6	38.6	44.2	65 dB(A)	65.6	34.7	41.2

**Note:**

- \* Day Time is reckoned between 6 A.M and 10 P.M
- \* Night Time is reckoned between 10 P.M and 6 A.M
- \*  $L_{eq}$  It is energy mean of the noise level over a specified period.
- \* \*dB (A)  $L_{eq}$  denotes the time weighted average of the level of sound in decibels on scale A which is relative to human hearing.
- \* A "decibel" is a unit in which noise is measured.
- \* "A", in dB (A)  $L_{eq}$ , denotes the frequency weighting in the measurement of noise and corresponds to Frequency response characteristics of the human ear.

REMARKS	As per CPCB Standards, Report Status: - The measured values for the above Locations are within the standards.
---------	--

\*\*\*End of Report\*\*\*

*OR*  
*Cond*  
636210

Reviewed By

*[Signature]*



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

*[Signature]*

Authorised Signatory

- NOTE:**
1. The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  2. Total liability of our institute is limited to the invoice amount.
  3. Samples will be disposed after the specified retention period.
  4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  5. Sample (s) or not drawn by us unless otherwise stated.



## Ganesh Consultancy & Analytical Services (OPC) Private Limited

Laboratory : 294A, Hebbal Industrial Area, Mysuru - 570 016 Telephone : 2402086, 4282027 Mobile : 9148337886  
 Office : 1030, Geetha Road, Chamarajapuram, Mysuru - 570 005 Telephone : 2402087, 4253825  
 Bengaluru Office : # 895, 2nd B Cross, Hosakere Halli, BSK 3rd Stage, Bengaluru - 560 085  
 Email : [info@ganeshlaboratory.com](mailto:info@ganeshlaboratory.com), [lab.ganesh@gmail.com](mailto:lab.ganesh@gmail.com) • Web : [www.ganeshlaboratory.com](http://www.ganeshlaboratory.com)

### TEST REPORT

#### AMBIENT NOISE LEVEL MONITORING REPORT

- |                                    |  |
|------------------------------------|--|
| 1. Name of the Company             | INFOSYS LTD. HEBBAL INDUSTRIAL AREA, MYSORE - 570 016. |
| 2. Sample Collected by             | Lab. Personnel   |
| 3. Date of Collection              | 11-03-2025 -- 06:00 AM to 12-03-2025 05:59 AM          |
| 4. Particulars of Sample Collected | Ambient Noise Level Monitoring                         |
| 5. Date of Sample Receipt          | 12-03-2025   |
| 6. Sample Number                   | C-04188  |
| 7. Method Adopted                  | IS:4758:1968 RA:2002                                   |

Sample Location	Day Time Noise Level (PCB Limit)	Day time Noise Level (Monitored value 6 AM to 10 PM)			Night Time Noise Level (PCB Limit)	Night time Noise Level (Monitored value 10 PM to 6 AM)		
		Max.	Min.	Leq in dB(A)		Max.	Min.	Leq in dB(A)
HF-3 B No.77 & 78 area	86 dB(A)	71.6	41.4	52.0	55 dB(A)	51.9	32.1	44.0

**Notes :**

- Day Time is reckoned between 6 A.M and 10 P.M
- Night Time is reckoned between 10 P.M and 6 A.M
- $L_{eq}$ : It is energy mean of the noise level over a specified period.
- \*dB (A)  $L_{eq}$  denotes the time weighted average of the level of sound in decibels on scale A which is relative to human hearing.
- A "decibel" is a unit in which noise is measured.
- "A", in dB (A)  $L_{eq}$  denotes the frequency weighting in the measurement of noise and corresponds to Frequency response characteristics of the human ear.

<b>REMARKS</b>	As per CPCB Standards, Report Status: - The measured values for the above Locations are within the standards.
----------------	--

\*\*\*End of Report\*\*\*

Reviewed By

*Blauy*



For GANESH CONSULTANCY & ANALYTICAL SERVICES  
(OPC) PRIVATE LIMITED

*Harees*

Authorised Signatory

- NOTE:**
1. The results listed refer only to the tested samples and applicable parameters. Endorsement of products neither inferred nor implied.
  2. Total liability of our institute is limited to the invoice amount.
  3. Samples will be disposed after the specified retention period.
  4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in Court of Law without prior permission in writing.
  5. Sample (s) or not drawn by us unless otherwise stated.

