

ITL/TVM/FAC/SEZ/017/2021

24<sup>th</sup> May 2021

The Director – IA, III.  
Room No. 524, 5th Floor,  
The Ministry of Environment & Forest (MOEF),  
Paryavaran Bhavan, C.G.O Complex, Lodhi Road,  
New Delhi – 110 033


Dear Sir,

Sub: Six monthly post ECC - Operation and construction phase monitoring report for the period of October-2020 to March-2021 of Software Development IT Park (SEZ) at Attippra Village, Trivandrum District.

Reference: ECC No: 647/SEIAA/EC1/4943/2013 dated 16.02.2016

With reference to the above, please find enclosed the copy of the report submitted to SEIAA Trivandrum on 24<sup>th</sup> May 2021 for the project with relevant annexures.

Thanking You,  
Yours Faithfully



Devi Padmanabhan Nair  
Regional Manager – Facilities



**Enclosures:**

1. MOEF report sent via mail to SEIAA dated 24<sup>th</sup> May 2021.
2. Reports –
  - Annexure-1: STP outlet sample analysis report
  - Annexure-2: UGR Out sample analysis report
  - Annexure-3: Ambient air quality report
  - Annexure-4: DG Stack emission report
  - Annexure-5: Noise level monitoring report
  - Annexure-6: Solar Power generated details

**INFOSYS LIMITED**  
SEZ Unit 1, Plot No. 1  
Technopark Campus II  
Attippra Village  
Thiruvananthapuram 695 583, India  
T 91 471 398 2222  
F 91 471 241 6177

Corporate Office:  
CIN: L85110KA1981PLC013115  
44, Infosys Avenue  
Electronics City, Hosur Road  
Bengaluru 560 100, India  
T 91 80 2852 0261  
F 91 80 2852 0362  
askus@infosys.com  
www.infosys.com

ITL/TVM/FAC/SEZ/016/2021

24<sup>th</sup> May 2021

The Administrator,  
State Environment Impact Assessment Authority (SEIAA),  
K.S.R.T.C Bus Terminal Complex,  
4th Floor, Thampanoor,  
Thiruvananthapuram - 695 001


Dear Sir,

Sub: Six monthly post ECC - Operation and construction phase monitoring report for the period of October-2020 to March-2021 of Software Development IT Park (SEZ) at Attippra Village, Trivandrum District.

Reference: ECC No: 647/SEIAA/EC1/4943/2013 dated 16.02.2016

Please find enclosed Six months' report for the project with relevant annexures.

Thanking You,  
Yours faithfully

  
Dev Padmanabhan Nair  
Regional Manager – Facilities



**Enclosures:**

1. Reports –
  - Annexure-1: STP outlet sample analysis report
  - Annexure-2: UGR Out sample analysis report
  - Annexure-3: Ambient air quality report
  - Annexure-4: DG Stack emission report
  - Annexure-5: Noise level monitoring report
  - Annexure-6: Solar Power generated details

**INFOSYS LIMITED**  
SEZ Unit 1, Plot No. 1  
Technopark Campus II  
Attippra Village  
Thiruvananthapuram 695 583, India  
T 91 471 398 2222  
F 91 471 241 6177

Corporate Office:  
CIN: L85110KA1981PLC013115  
44, Infosys Avenue  
Electronics City, Hosur Road  
Bengaluru 560 100, India  
T 91 80 2852 0261  
F 91 80 2852 0362  
askus@infosys.com  
www.infosys.com

**MoEF report for Construction Phase& Operation Phase (SEZ) Oct'20 to Mar'21.**

Sl No.	Conditions Imposed	Compliance taken by us																														
Water																																
1.	Water requirement & sources	Water is sourced through Technopark which is treated and stored in Underground reservoir for operation. Sewage water is treated at the STP within the campus.																														
2.	RWH units	Towards collecting rainwater, 2 ponds have been created with a total capacity of 36118cum inside the campus with proper side pitching and desilting.																														
3.	Facilities for liquid waste treatment	Sewage generated in the campus is treated through Sewage Treatment Plant (STP) of capacity 500KLD which is based on Membrane Bio Reactor Technology (MBR). Recycled water from Sewage treatment plant will be utilized for Irrigation, flushing & cooling purposes. Treated water quality confirms to KSPCB prescribed standard (Annexure 1). <b>STP Outlet Report detail: Feb 2021.</b> <table><tr><th>Parameter</th><th>Stipulated Limit</th><th>Results</th></tr><tr><td>Ph</td><td>6.5 to 8.5</td><td>7.06</td></tr><tr><td>TSS in MG/L</td><td>20 mg/l</td><td>BDL</td></tr><tr><td>Oil and Grease</td><td>1 mg/l</td><td>BDL</td></tr><tr><td>BOD in mg/l</td><td>3 mg/l</td><td>2.2 mg/l</td></tr><tr><td>E-Coli</td><td>NIL</td><td>Absent</td></tr><tr><td>Residual Chlorine</td><td>1.0 mg/l</td><td>0.8 mg/l</td></tr><tr><td>COD in mg/l</td><td>20 mg/l</td><td>10 mg/l</td></tr><tr><td>TDS in mg/l</td><td>2100 mg/l</td><td>286 mg/l</td></tr><tr><td>Odour</td><td>No Odour</td><td>No Odour</td></tr></table>	Parameter	Stipulated Limit	Results	Ph	6.5 to 8.5	7.06	TSS in MG/L	20 mg/l	BDL	Oil and Grease	1 mg/l	BDL	BOD in mg/l	3 mg/l	2.2 mg/l	E-Coli	NIL	Absent	Residual Chlorine	1.0 mg/l	0.8 mg/l	COD in mg/l	20 mg/l	10 mg/l	TDS in mg/l	2100 mg/l	286 mg/l	Odour	No Odour	No Odour
Parameter	Stipulated Limit	Results																														
Ph	6.5 to 8.5	7.06																														
TSS in MG/L	20 mg/l	BDL																														
Oil and Grease	1 mg/l	BDL																														
BOD in mg/l	3 mg/l	2.2 mg/l																														
E-Coli	NIL	Absent																														
Residual Chlorine	1.0 mg/l	0.8 mg/l																														
COD in mg/l	20 mg/l	10 mg/l																														
TDS in mg/l	2100 mg/l	286 mg/l																														
Odour	No Odour	No Odour																														
4.	Impoundment, damming, culverting, realignment or other changes to the hydrology of watercourses or aquifers	No impoundment, damming, realignment or other changes to the hydrology of surface water courses is done. We have a thodu/canal passing through the campus, which has been maintained and water flow has been enhanced by pitching with additional culvert in the downstream In addition to this, yearly desilting of Thodu is done for ensuring free flow of water.																														
5.	Water quality meeting requirements	Monthly monitoring is carried out through a PCB approved external agency to ensure that the water quality meets IS 10500 requirement and reports attached for the last 6 months (Oct’20 to Mar’21) and maintained at site. (Annexure 2).																														
6.	Provisions for use of recycled water	Recycled water from STP is utilized for irrigation, flushing and cooling requirements within the campus.																														
LAND																																
7.	Access road to the site –Width & Condition	Main Access road to the site is through NH-66 by-pass and service road available for easy entry to the site. For safety movement of the pedestrians and vehicles, crash barriers and traffic signals are placed along the service road and at the NH Sides																														
8.	Storage of explosives/hazardous substances	All precautionary measures have been taken and also obtained valid license from Petroleum and Explosives Safety Organization (PESO) for storage of HSD valid till 31 <sup>st</sup> Dec 2030. An addition to this Fire NOC Obtained and valid till Dec 2022.																														
9.	Facility for solid waste management.	In Operation phase as part of solid waste management, segregation is achieved at source by provision of signage’s, color coded bins and the same is stored and disposed asper the standards. The food waste generated is fed in to 350kg capacity digester biogas plant. <table><tr><th>Type of Waste</th><th>Avg quantity (Oct’20 to Mar’21)</th></tr><tr><td>Food Waste</td><td>386.21kg/month</td></tr></table>	Type of Waste	Avg quantity (Oct’20 to Mar’21)	Food Waste	386.21kg/month																										
Type of Waste	Avg quantity (Oct’20 to Mar’21)																															
Food Waste	386.21kg/month																															
10.	Proneness to natural hazardous.	As per the Indian Standards Seismic Zoning Map, the campus area comes under Zone – III, moderate damage risk zone. Scheduled Mock drills are conducted so as to make the employees aware on what to do in case of an emergency. Safe Assembly point identified to accommodate all the employees safely in one place in case of an emergency.																														

11.	Topsoil, overburden etc.	The topsoil is used for landscaping work. Overburden is used for back filling and road construction purposes inside campus itself.													
AIR															
12.	Air quality meeting requirements	Dust emission from construction phase	<p>Provision of GI Sheets/green shade as barrication for controlling dust. Also regular monitoring of air quality is done and report maintained.</p> <p><b>Ambient Air Quality Report: Mar'21</b></p> <table><tr><th colspan="3">Ambient Air Quality (in between SDB 1 &amp; SDB 2)</th></tr><tr><th>Parameter</th><th>Stipulated Limit</th><th>Results</th></tr><tr><td>Particulate Matter (PM10)</td><td>100 µg/m³</td><td>65.8 µg/m³</td></tr></table> <p>Ambient air reports - (Annexure 3).</p>	Ambient Air Quality (in between SDB 1 & SDB 2)			Parameter	Stipulated Limit	Results	Particulate Matter (PM10)	100 µg/m³	65.8 µg/m³			
		Ambient Air Quality (in between SDB 1 & SDB 2)													
Parameter	Stipulated Limit	Results													
Particulate Matter (PM10)	100 µg/m³	65.8 µg/m³													
		Emissions from combustion of fossil fuels	<p>There is no major air pollutant generating source except DG sets and vehicular movement during construction and operation phase.</p> <p>It is ensured that transportation of construction materials is done only during non-peak hours.</p> <p>DG's are used as backup power generation in case of Grid power failure. Appropriate stacks with stipulated height is provided for DG's as Air pollution control measures. Monthly monitoring of stack emission is done and reports attached for last 6 months (Oct'20 to Mar'21) and report maintained. (Annexure 4).</p> <p><b>Stack Monitoring Report Detail – Mar'21 (DG II PII)</b></p> <table><tr><th>Parameter</th><th>Stipulated Limit</th><th>Results</th></tr><tr><td>Particulate Matter</td><td>150 mg/ Nm³</td><td>24 mg/ Nm³</td></tr><tr><td>Sulphur Dioxide</td><td>50 mg/ Nm³</td><td>46 mg/ Nm³</td></tr><tr><td>Oxides of Nitrogen</td><td>450 mg/ Nm³</td><td>32 mg/ Nm³</td></tr></table>	Parameter	Stipulated Limit	Results	Particulate Matter	150 mg/ Nm³	24 mg/ Nm³	Sulphur Dioxide	50 mg/ Nm³	46 mg/ Nm³	Oxides of Nitrogen	450 mg/ Nm³	32 mg/ Nm³
Parameter	Stipulated Limit	Results													
Particulate Matter	150 mg/ Nm³	24 mg/ Nm³													
Sulphur Dioxide	50 mg/ Nm³	46 mg/ Nm³													
Oxides of Nitrogen	450 mg/ Nm³	32 mg/ Nm³													
13.	Noise level meeting requirements	<p>➤ During Construction Phase: There will be some noise generated due to cutting of marble and other stone materials</p> <p>➤ Uninterrupted movement of heavy and light vehicles at high speeds may cause increase in ambient noise levels on the project road (No significant impacts)</p>	<p>➤ Marble and Tiles are located far away from the operational phase, ie at designated area thereby decreasing the effect of noise pollution. Workers are equipped with Personal Protective equipment's (PPE's).</p> <p>➤ It is ensured that good conditioned vehicles are used for transporting construction materials thereby resulting in decrease of noise levels, also strictly following the speed limit of 20km/hr and securities posted to keep a check on vehicle speeding. Transportation is during non-peak hours.</p> <p>➤ Monthly noise monitoring is done and reports attached for last 6months (Oct'20 to Mar'21). (Annexure 5).</p>												
14.	Likely emissions effecting environment	There is no major air pollutant generating source. DG's are used as backup power generation in case of Grid power failure. Appropriate stacks with stipulated height is provided for DG's as Air pollution control measures. Monthly monitoring of stack emission is done and reports attached for last 6 months (Oct'20 to Mar'20) and report maintained. (Annexure 4).													

15.	Hazardous waste generation and management	Hazardous wastes generated are collected, stored and disposed through CPCB & KSPCB authorized vendors. A designated Scrap Yard available inside campus for storing the Hazardous and Non-Hazardous waste generated.
-----	---	---

ENERGY																																										
16.	Energy requirement & source	Source of Power supplied to the campus is through Technopark. DG has been installed which is used as backup power generation in case of Grid power failure. Average Power consumption for (Oct'20 to Mar'21) is 374,686 kwh/month i.e. 27% reduction compared to the period, Apr'20 to Sep'20.																																								
17.	Extent of usage of alternative energy resources	Grid connected Solar panels of 826kwp has been installed which caters to 27% of total campus power consumption for the period of (Oct'20 to Mar'21) Monthly Power generation from solar power has been attached. (Annexure 6). Average Solar power generated for (Oct'20 to Mar'21) is 101985kwh/month. In addition to this, Solar power generated on weekends and public holidays are exported to Technopark.																																								
BIODIVERSITY																																										
18.	Presence of any endangered species or red listed category	<p>Unique initiative towards safeguarding <b>Rare Endangered and Threatened (RET) species</b> of native plants / trees is taken up. A dedicated area of approx. 1.5 acres is planted with RET species and medicinal plants like black vasa, ayapana, aloe vera, vasaka, black pepper.</p> <table border="1"> <thead> <tr> <th>Plant Name</th><th>Common Name</th><th></th></tr> </thead> <tbody> <tr> <td>Hopea parviflora</td><td>Kambakam</td><td rowspan="9">Trees</td></tr> <tr> <td>Vateria indica</td><td>White Dammar</td></tr> <tr> <td>Aphanamixis polystachya</td><td>Chemmaram</td></tr> <tr> <td>Alstonia scholaris</td><td>Indian Devil Tree</td></tr> <tr> <td>Calophyllum Inophyllum</td><td>Pinna</td></tr> <tr> <td>Pterocarpus santalinus</td><td>Red sandal wood</td></tr> <tr> <td>Caryota urens</td><td>Choondappana</td></tr> <tr> <td>Saraca asoca</td><td>Ashoka chetthi</td></tr> <tr> <td>Terminalia bellirica</td><td>Thanni</td></tr> <tr> <td>Garcinia talboti</td><td>Malabar Tamarind</td><td rowspan="7">Saplings</td></tr> <tr> <td>Diospyros buxifolia</td><td>Kattathovara</td></tr> <tr> <td>Artocarpus lakoocha</td><td>Wild Anjali</td></tr> <tr> <td>Hydnocarpus pentandra</td><td>Marotti</td></tr> <tr> <td>Barringtonia racemosa</td><td>Samudrachampa</td></tr> <tr> <td>Terminalia arjuna</td><td>Neermaruthu</td></tr> <tr> <td>Butea monosperma</td><td>Flame of the forest</td></tr> <tr> <td>Diospyros pentandra</td><td>—</td><td></td></tr> </tbody> </table>	Plant Name	Common Name		Hopea parviflora	Kambakam	Trees	Vateria indica	White Dammar	Aphanamixis polystachya	Chemmaram	Alstonia scholaris	Indian Devil Tree	Calophyllum Inophyllum	Pinna	Pterocarpus santalinus	Red sandal wood	Caryota urens	Choondappana	Saraca asoca	Ashoka chetthi	Terminalia bellirica	Thanni	Garcinia talboti	Malabar Tamarind	Saplings	Diospyros buxifolia	Kattathovara	Artocarpus lakoocha	Wild Anjali	Hydnocarpus pentandra	Marotti	Barringtonia racemosa	Samudrachampa	Terminalia arjuna	Neermaruthu	Butea monosperma	Flame of the forest	Diospyros pentandra	—	
Plant Name	Common Name																																									
Hopea parviflora	Kambakam	Trees																																								
Vateria indica	White Dammar																																									
Aphanamixis polystachya	Chemmaram																																									
Alstonia scholaris	Indian Devil Tree																																									
Calophyllum Inophyllum	Pinna																																									
Pterocarpus santalinus	Red sandal wood																																									
Caryota urens	Choondappana																																									
Saraca asoca	Ashoka chetthi																																									
Terminalia bellirica	Thanni																																									
Garcinia talboti	Malabar Tamarind	Saplings																																								
Diospyros buxifolia	Kattathovara																																									
Artocarpus lakoocha	Wild Anjali																																									
Hydnocarpus pentandra	Marotti																																									
Barringtonia racemosa	Samudrachampa																																									
Terminalia arjuna	Neermaruthu																																									
Butea monosperma	Flame of the forest																																									
Diospyros pentandra	—																																									
19.	Loss of native species and genetic diversity	As a responsible corporate large number of saplings of native fruit species like Jamun, Mosambi, Mangoes, Custard Apple, Pomegranate, Amla, Sapotta, Guava, Neem, Kadamba, Jack fruit, Soursop, Ramboutan and shrubs like Ixora, Jasmine, Tecoma, Hibiscus, Kanakambaram etc are planted inside campus so as to conserve the biodiversity.																																								
20.	Likely displacement of fauna	Not Applicable.																																								
21.	Any introduction of alien/ invasive species	Nil.																																								

SOCIAL ASPECTS		
22.	Proximity to nearest habitation	Campus is located within Trivandrum Corporation limits surrounded by UST, NH Bypass and Residential houses.
23.	CSR Activities	<ul style="list-style-type: none"> <li>As part of the current pandemic situation (Covid-19) 70 Pulse Oximeters were donated to District Collector's office for supporting the Department of Health -27th October 2020.</li> <li>2 LED TVs were donated to students from Tribal School in Indinjar, Palode Thiruvananthapuram -27th November 2020.</li> <li>Documentary screening on Travancore Observatory was organized along with interactive session with Mr. Anand Narayanan, Associate Professor at the Indian Institute of Space Science and Technology on 23rd January 2021.</li> <li>Debate competitions which spanned across 8 weeks for the beneficiaries from Govt Schools in Kulathoor &amp; Pattom as well Prathibha Poshini, a Trivandrum based Institution.</li> <li>As part of Vijnana, weekend sessions like Elocution competition, Letter writing, Word puzzle, Proverbs, Essay writing, Indian states and Capital, Write up about festivals, Kerala History- Important years, Write up Indian states and their Festivals, Anagram, Write up about favorite Book, Countries and Continents, Cross word , Letter and number series, Quiz, English word activities, Fill in the blanks, English word activities, Fill in the blanks, Essay writing, Number series and word games were organized at Govt HSS, Kulathoor , Thiruvananthapuram.</li> <li>A seminar for college students was organized to make understand the importance and overview on CSR.</li> <li>An Online quiz competition was organized at Kulathoor GHSS and Pattom GHSS, Trivandrum on 2nd October 2020 on account of Gandhi Jayanthi.</li> <li>On account of Christmas and New year, "Make a Wish" was organized to gift wishes across 18 organizations, covering 915 beneficiaries.</li> </ul>
24.	Environment Management plan/ Eco restoration plan (brief details)	<p>As part of Environment management, the following measures have been taken:</p> <ul style="list-style-type: none"> <li>An online initiative, "Home Gardening &amp; its best practices!", started which allows employees to showcase their organic farming efforts at home. This is done basically to motivate employees to start their own organic farming at home.</li> <li>An online session on Aquaponics and Fish farming was organized for employees., to learn the basic theory of fish farming and aquaponics farming.</li> <li>As part of water saving initiative, a webinar session was conducted to understand the cost- effective models of rainwater harvesting systems both at homes and community at large.</li> <li>Considering the pandemic situation, an online initiative was organized wherein employees could send in photos of birds visiting their house. This would initially be put-up in the web gallery of "Green Team".</li> <li>Sewage generated in the campus is treated through Sewage Treatment Plant (STP) which is based on Membrane Bio Reactor Technology (MBR).</li> <li>As a responsible corporate, we have increased the renewable source (solar) to 826kWp which caters to 27% of total power consumption.</li> <li>Considering this pandemic situation, an effective monitoring and study of indoor air quality is done in addition to the regular checks.</li> <li>As a responsible corporate, plastic garbage bag has been replaced with bio-degradable bags &amp; gunny bags, replaced the PET drinking bottles with glass and steel bottles also replacement of Single use plastic pens with Paper pens.</li> <li>Food waste generated is fed to Biogas plant wherein the generated biogas is used for cooking purpose</li> </ul>

25.	Biomedical waste management	<p>Bio-medical waste generated within the campus is disposed through IMAGE. Color coded bins are placed inside Med center with markings for proper segregation at source.</p> <p>A software application “IMAGE HCE PORTAL 1.0” has been implemented for tracking the end disposal of Biomedical waste.</p> <p>Abiding by the Biomedical waste rule, Used masks and gloves are separated from the biomedical waste and quantified and disposed through IMAGE.</p> <p>All Biomedical waste handlers has been immunized with Hepatitis B and Tetanus Vaccination.</p> <p>Details on the disposal is been submitted to KSPCB through Form IV annually.</p> <table><tr><td>Bio Medical Waste</td><td>Avg (Oct’20 to Mar’21)</td></tr><tr><td colspan="2">20.23 kg/month</td></tr></table>	Bio Medical Waste	Avg (Oct’20 to Mar’21)	20.23 kg/month	
Bio Medical Waste	Avg (Oct’20 to Mar’21)					
20.23 kg/month						
26.	E-waste management	<p>E-wastes generated are collected, stored and disposed through CPCB &amp; KSPCB authorized vendors.</p> <p>Details on the disposal is been submitted to SPCB through Form III annually.</p>				
27.	Litigation, if any, against the project	No.				

**SPECIFIC CONDITIONS: -**

Sl. No.	Conditions	
1.	The Emergency parking facility proposed should be ear marked.	Yes, it is ear marked. In every floor of Multi level parking lot (MLPL) a designated emergency parking space is identified and ear marked.
2.	Adequate drinking water and sanitary facilities should be provided for construction workers at the site. Provision should be made for mobile toilets. The safe disposal of wastewater and solid wastes generated during the construction phase should be ensured.	<p>Drinking water facilities are provided at construction site.</p> <p>Sanitary facilities are also provided and are connected to the STP.</p> <p>Labors are provided with labor camp facility with dedicated room, cooking area, drinking water facility and toilets.</p>
3.	Disposal of muck during construction phase should not create any adverse effect on the neighboring communities and be disposed taking the necessary precautions for general safety and health aspects of people, only in approved sites with the approval of competent authority.	The muck will be used for refilling the low-lying areas in the project premised. Used for the development of internal roads.
4.	Construction spoils, including bituminous material and other hazardous materials, must not be allowed to contaminate water courses and the sump sites for such materials must be secured so that they should not leach into the ground water.	Construction spoils and hazardous materials generated are stored in a safe and secured manner. The placement is on concrete base thereby eliminating any chance of contamination to the water courses.
5.	Any hazardous waste generated during construction phase, should be disposed of as per applicable rules and norms with necessary approvals of Kerala State Pollution Control Board.	Yes, disposed off as per applicable KSPCB rules and norms received.
6.	The diesel generator sets to be used during construction phase should be low Sulphur diesel type and should conform to Environment (Protection) rules prescribed for air and noise emission standards.	<p>DG's are used as backup power generation in case of Grid power failure.</p> <p>DG's are located in secluded areas with proper acoustic facility and with appropriate stacks with stipulated height which acts as Air pollution control measures.</p>
7.	Water demand during construction should be reduced by use of pre-mixed concrete, curing agents and other best practices referred.	Yes, pre-mixed concrete is used.



8.	Roof should meet prescriptive requirement as per Energy Conservation Building Code by using appropriate thermal insulation material to fulfil requirement.	Yes, Energy Conservation Building Code is followed.
----	--	---

**GENERAL CONDITIONS: -**

Sl. No.	Conditions	
(i)	Rain water Harvesting capacity should be installed as per the prevailing provisions of KMBR/ KPMR, unless otherwise specified elsewhere.	2 ponds have been created with a total capacity of 36118cum inside the campus with proper side pitching and desilting towards collecting rain water. Open drains are also created along the rear periphery wall towards collecting the run-off water from the neighborhood.
(ii)	Environment Monitoring Cell as agreed under the affidavit filed by the proponent should be formed and made functional.	Yes, formed and functional.
(iii)	Suitable avenue trees should be planted along either side of the tarred road and open parking areas, if any, inclusive of approach road and internal roads.	Avenue trees like Mimusops elengi, Ficus benjamina and Ficus panda are planted in the service roads outside campus for public environmental welfare. Trees like Neem, Kadambu, Ezhilampala, Lakshmitharu, Jack fruit, Fig, Coconut, Water apple are the avenue trees cum fruit trees and trees such as samanea saman, spathodia, Mimusops elengi are also planted inside campus which is preserved and nurtured well. Shade trees has been provided along the NH service road. The NH has been planted with flowering plant in the concern with NHAI.
(iv)	The project shall incorporate devices for solar energy generation and utilization to the maximum possible extent with the possibility of contributing the same to the national grid in future.	Grid connected Solar panels of 826kw has been installed which caters to 27% of total campus power consumption. Solar power generated on weekends and public holidays are exported to Technopark.
(v)	Safety measures should be implemented as per the Fire and Safety Regulations.	Yes, safety measures are implemented as directed by Department of Fire & Rescue services. Annual Renewal of the certificate is carried out by FRS after necessary site inspections. All buildings are equipped with Sprinkler systems, hose reels, wet risers, smoke & fire alarm system. External fire hydrants provided around the buildings across the campus. Exclusive fire tanks maintained atop all the high rise buildings in addition to the fire tanks available in our Underground reservoirs. Fire extinguishers are provided as per IS 2190 standard and sand buckets are provided at prominent places.
(vi)	STP should be installed and made functional as per KSPCB guidelines including that for solid waste management	Yes, it's installed. Sewage generated in the campus is treated in the Sewage Treatment Plant (STP) of capacity 500KLD. The STP is based on Membrane Bio Reactor (MBR) technology. Recycled water from Sewage treatment plant will be utilized for landscaping, flushing and cooling tower purpose. Treated water quality confirms to KSPCB required standard. Proper facilities are provided inside campus for solid waste management. The food waste generated is fed in to 350kg capacity digester biogas plant biogas. The dry waste generated is disposed through authorized dealer.



		Adequate number of collection bins are provided for bio-degradable waste. Have also ensured that the solid waste generated is segregated at source.
(vii)	The conditions specified in the Companies Act, 2013 should be observed for Corporate Social Responsibility.	Yes, Complied.
(viii)	The proponent should plant trees at least 5 times of the loss that has been occurred while clearing the land for the project.	Yes, saplings comprising of native fruit species and shrubs has been planted inside campus, so as to conserve the biodiversity.
(ix)	Consent from Kerala State Pollution Control Board under Water and Air Act(s) should be obtained before initiating activity.	Yes, obtained.
(x)	All other statutory clearances should be obtained, as applicable, by project proponents from the respective competent authorities including that for blasting and storage of explosives.	Yes, obtained. Possessing valid license from Petroleum and Explosives Safety Organization (PESO) for storage of HSD valid till 31 <sup>st</sup> Dec 2030.
(xi)	In the case of any change(s) in the scope of the project, the project would require a fresh appraisal by this Authority.	No change in the Scope of the proposed project.
(xii)	The Authority reserves the right to add additional safeguard measures subsequently, if found necessary, and to take action including revoking of the environment clearance under the provisions of the Environment (Protection) Act, 1986, to ensure effective implementation of the suggested safeguard measures in a time bound and satisfactory manner.	Yes, agreed.
(xiii)	The stipulations by Statutory Authorities under different Acts and Notification should be complied with, including the provisions of Water (Prevention and Control of Pollution) Act, 1974, the Air (Prevention and control of Pollution) act 1981, the Environment (Protection) Act, 1986, the Public Liability (Insurance) Act, 1991 and EIA Notification, 2006.	Yes, complied.
(xiv)	The proponent shall submit half yearly reports on the status of compliance of the stipulated EC conditions including results of monitored data (both in hard copies as well as by e-mail). It shall simultaneously be sent to the respective Regional Office of MoEF, Govt. of the India and also to the Directorate of Environment and Climate Change, Govt. of Kerala.	Half yearly report submitted to Regional Office of MoEF and to Directorate of Environment and Climate change, Govt of Kerala.
(xv)	<u>The details of Environmental Clearance should be prominently displayed in a metallic board of 3 ft. x 3 ft. with green background and yellow letters of Times New Roman font of size of not less than 40.</u>	Yes, the details of EC are prominently displayed.